



Legislation Details (With Text)

File #:	Int 0644-2018	Version:	A	Name:	Requiring carbon monoxide detectors in commercial spaces.
Type:	Introduction	Status:	Enacted	In control:	Committee on Housing and Buildings
On agenda:	3/7/2018				
Enactment date:	12/1/2018	Enactment #:	2018/191		
Title:	A Local Law to amend the administrative code of the city of New York and the New York city building code, in relation to requiring carbon monoxide detectors in commercial spaces				
Sponsors:	Mathieu Eugene, Ben Kallos, Helen K. Rosenthal, Costa G. Constantinides, Margaret S. Chin				
Indexes:					
Attachments:	1. Summary of Int. No. 644-A, 2. Summary of Int. No. 644, 3. Int. No. 644, 4. March 7, 2018 - Stated Meeting Agenda, 5. Hearing Transcript - Stated Meeting 03-07-18, 6. Minutes of the Stated Meeting - March 7, 2018, 7. Committee Report 6/12/18, 8. Hearing Testimony 6/12/18, 9. Hearing Transcript 6/12/18, 10. Proposed Int. No. 644-A - 10/26/18, 11. Committee Report 10/31/18, 12. Hearing Transcript 10/31/18, 13. Committee Report - Stated Meeting, 14. October 31, 2018 - Stated Meeting Agenda with Links to Files, 15. Hearing Transcript - Stated Meeting 10-31-18, 16. Minutes of the Stated Meeting - October 31, 2018, 17. Int. No. 644-A (FINAL), 18. Fiscal Impact Statement, 19. Legislative Documents - Letter to the Mayor, 20. Local Law 191				

Date	Ver.	Action By	Action	Result
3/7/2018	*	City Council	Introduced by Council	
3/7/2018	*	City Council	Referred to Comm by Council	
6/12/2018	*	Committee on Housing and Buildings	Hearing Held by Committee	
6/12/2018	*	Committee on Housing and Buildings	Laid Over by Committee	
10/31/2018	*	Committee on Housing and Buildings	Hearing Held by Committee	
10/31/2018	*	Committee on Housing and Buildings	Amendment Proposed by Comm	
10/31/2018	*	Committee on Housing and Buildings	Amended by Committee	
10/31/2018	A	Committee on Housing and Buildings	Approved by Committee	Pass
10/31/2018	A	City Council	Approved by Council	Pass
10/31/2018	A	City Council	Sent to Mayor by Council	
12/1/2018	A	Administration	City Charter Rule Adopted	
12/3/2018	A	City Council	Returned Unsigned by Mayor	

Int. No. 644-A

By Council Members Eugene, Kallos, Rosenthal, Constantinides and Chin

A Local Law to amend the administrative code of the city of New York and the New York city building code, in relation to requiring carbon monoxide detectors in commercial spaces

Be it enacted by the Council as follows:

Section 1. Article 315 of chapter 3 of title 28 of the administrative code of the city of New York is amended to add a new section 28-315.11 to read as follows:

28-315.11 Buildings that are equipped with a fire alarm system and that contain Group A-1, A-2, A-3, Group B or Group M occupancies. By January 1, 2021, existing buildings equipped with a fire alarm system and that contain group A-1, A-2 or A-3, Group B or Group M occupancies shall comply with the retroactive requirements of section 908.7.3.1 of the New York city building code.

§ 2. Section 908.7.3 of the New York city building code, as amended by local law number 10 for the year 2014, is amended to read as follows:

908.7.3 Buildings that are equipped with a fire alarm system and that contain Group A-1, A-2, A-3, [or certain] Group B or Group M occupancies. Listed carbon monoxide detectors shall be installed in buildings that are equipped with a fire alarm system and that contain Group A-1, A-2 or A-3, [occupancies or assembly spaces classified as] Group B or Group M occupancies [in accordance with Section 303.1, Exception 1]. Such carbon monoxide detectors installed pursuant to this section shall have built-in sounder bases, shall transmit a signal to a central supervising station and shall be permitted to initiate an audible and visual supervisory alarm at a constantly attended location. The department shall adopt rules and/or reference standards (i) governing the installation and location of carbon monoxide detectors, provided that such detectors shall be required within rooms containing carbon-monoxide producing equipment [.] and (ii) addressing the installation of such detectors or any alternative means of compliance in existing buildings.

Exception: Carbon monoxide detectors shall not be required in kitchens.

908.7.3.1 Retroactive provisions for existing buildings. Notwithstanding any other provision of law, listed carbon monoxide detectors shall be installed in existing buildings that are equipped with a fire alarm system and that contain group A-1, A-2, A-3, Group B or Group M occupancies in accordance with Section 908.7.3 by January 1, 2021.

§ 3. This local law takes effect 270 days after it becomes law, except that the commissioner of buildings may take such measures as are necessary for its implementation, including the promulgation of rules, prior to such effective date.

MPC/APB
LS 843/Int. No. 1771-2017
10/9/18 5:05pm
LS 710