



Legislation Details (With Text)

File #: Int 1746-2019 **Version:** * **Name:** Operation of gas-fired low-pressure boilers.
Type: Introduction **Status:** Filed (End of Session)
In control: Committee on Housing and Buildings

On agenda: 10/17/2019

Enactment date: **Enactment #:**

Title: A Local Law to amend the administrative code of the city of New York, in relation to the operation of gas-fired low-pressure boilers

Sponsors:

Indexes:

Attachments: 1. Summary of Int. No. 1746, 2. Int. No. 1746, 3. October 17, 2019 - Stated Meeting Agenda with Links to Files, 4. Hearing Transcript - Stated Meeting 10-17-19, 5. Minutes of the Stated Meeting - October 17, 2019, 6. Committee Report 12/2/20, 7. Hearing Testimony 12/2/20, 8. Hearing Transcript 12/2/20

Date	Ver.	Action By	Action	Result
10/17/2019	*	City Council	Introduced by Council	
10/17/2019	*	City Council	Referred to Comm by Council	
12/2/2020	*	Committee on Housing and Buildings	Hearing Held by Committee	
12/2/2020	*	Committee on Housing and Buildings	Laid Over by Committee	
12/2/2020	*	Committee on Fire and Emergency Management	Hearing Held by Committee	
12/2/2020	*	Committee on Fire and Emergency Management	Laid Over by Committee	
12/31/2021	*	City Council	Filed (End of Session)	

Int. No. 1746

By Council Members Levine, Brannan, Koslowitz, Ayala, Dromm, Kallos, Moya, Levin, Rosenthal, Adams, Cabrera, Rivera, Reynoso and Louis

A Local Law to amend the administrative code of the city of New York, in relation to the operation of gas-fired low-pressure boilers

Be it enacted by the Council as follows:

Section 1. Subdivision (a) of section 27-797 of the administrative code of the city of New York is amended to read as follows:

(a) Every oil burning installation that is not fully automatic or requires preheating and every gas-fired

low-pressure boiler that is not fully automatic shall be operated by, or under, the direct supervision of a person holding a certificate of fitness issued by the fire commissioner. Such person shall be in the building at all times while the burners are in operation, and shall be present in the boiler room during the starting of the operation of a boiler.

§ 2. This local law takes effect 60 days after it becomes law.

NAB
LS #9493
9/3/19